

Nuclide Analysis Results of Radioactive Materials in the Air  
at the Sites of Fukushima Nuclear Power Stations <1/2>

Reference

(Data summarized on December 15)

Place of Sampling	West Gate of Fukushima Daiichi NPS		MP-1 of Fukushima Daini (Reference)				②Density limit by the announcement of Reactor Regulation (Bq/cm <sup>3</sup> ) (Density limit in the air to which radiation workers breathe in the section 4 of the appendix 2)	
	Time of Sampling		Time of Sampling					
Detected Nuclides (Half-life)	①density of sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	①density of sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	①density of sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)		
	I-131 (about 8 days)	ND	-	ND	-			
Cs-134 (about 2 years)	ND	-	ND	-				2E-03
Cs-137 (about 30 years)	ND	-	ND	-			3E-03	

\* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

O.OE—O means O.O x 10-O

Data of other nuclides are under examination.

\* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

\* "ND" means the sampled data is below measurable limit.

Detection limits of 3 nuclides on the West Gate of Fukushima Daiichi are as follows:

Volatile: I-131: approx. 1E-7Bq/cm<sup>3</sup>, Cs-134: approx. 3E-7Bq/cm<sup>3</sup>, Cs-137: approx. 3E-7Bq/cm<sup>3</sup>      Particulate: I-131: approx. 7E-8Bq/cm<sup>3</sup>, Cs-134: approx. 2E-7Bq/cm<sup>3</sup>, Cs-137: approx. 2E-7Bq/cm<sup>3</sup>

Detection limits of 3 nuclides on MP-1 of Fukushima Daini are as follows:

Volatile: I-131: approx. 2E-6Bq/cm<sup>3</sup>, Cs-134: approx. 3E-6Bq/cm<sup>3</sup>, Cs-137: approx. 3E-6Bq/cm<sup>3</sup>      Particulate: I-131: approx. 7E-7Bq/cm<sup>3</sup>, Cs-134: approx. 2E-6Bq/cm<sup>3</sup>, Cs-137: approx. 1E-6Bq/cm<sup>3</sup>

Nuclide Analysis Results of Radioactive Materials in the Air  
at the Sites of Fukushima Nuclear Power Stations <2/2>

Reference

(Data summarized on December 15)

Place of Sampling	Environment Management Building, Fukushima Daiichi		Water Treatment Building, Fukushima Daiichi		Switching Yard of Unit 5 and 6, Fukushima Daiichi		②Density limit by the announcement of Reactor Regulation (Bq/cm <sup>3</sup> ) (Density limit in the air to which radiation workers breathe in the section 4 of the appendix 2)
Time of Sampling	2011/12/14 9:30~14:30		2011/12/14 9:51~14:51		2011/12/14 10:02~15:02		
Detected Nuclides (Half-life)	①density of sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	①density of sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	①density of sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (about 2 years)	ND	-	ND	-	1.8E-06	0.00	2E-03
Cs-137 (about 30 years)	ND	-	ND	-	2.0E-06	0.00	3E-03

\* The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

O.OE – O means O.O x 10-O

Data of other nuclides are under examination.

\* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

\* "ND" means the sampled data is below measurable limit.

The followings show the detection limits. Volatile: I-131: approx. 2E-7Bq/cm<sup>3</sup>, Cs-134: approx. 5E-7Bq/cm<sup>3</sup>, Cs-137: approx. 5E-7Bq/cm<sup>3</sup>

Particulate: I-131: approx. 1E-7Bq/cm<sup>3</sup>, Cs-134: approx. 3E-7Bq/cm<sup>3</sup>, Cs-137: approx. 3E-7Bq/cm<sup>3</sup>

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.