

Investigation result of data missing and others
for the Plant Data of Fukushima Daiichi and Daini Nuclear Power Station
at the time of Tohoku-Chihou-Taiheiyo-Oki Earthquake

(1) Fukushima Daiichi Nuclear Power Station (Data missing: 5, Data duplication: 3, Others [e.g. incorrect description]: 10)

Data	Unit (Homepage)	Data item	Time or page [before correction]	Check result (missing, duplication, and so on)	Responses [correction content]	
Chart	Unit 1	-	Reactor water level/ Reactor water level (Fuel range)	Page 1/3	Clarification of the recorder outage time	Supplemental explanation on recorder outage is added
		-	Reactor recirculation pump A/B inlet temperature	Page 1/2	Fluctuation of date and time description Clarification of the recorder outage time	Correction of date and time description Supplemental explanation on recorder outage is added
	Unit 2	-	DRYWELL MAKE-UP N2 FLOW / PRESS	Page 1/1	Incorrect description of the unit	Correction of unit description PCV nitrogen flow: (t/h → l/h)
		-	DRYWELL TEMPERATURE ATOMS	Pages 1/2 - 2/2	Incorrect description of the measurement item	Correction of description of the measurement item
		-	PCV atmospheric radiation monitor A, C	Pages 1/4 4/4	Fluctuation of date and time description Clarification of the recorder outage time	Correction of date and time description Supplemental explanation on recorder outage is added
	Unit 3	-	Turbine steam flow/ Reactor pressure	Page 3/3	Fluctuation of date and time description	Correction of date and time description
		-	Suppression chamber water level (at periodic inspection)	Page 1/1	Incorrect description of the unit	Correction of unit description Suppression chamber water level (at periodic inspection): (mm → cm)
		-	Radiation monitor at main exhaust stack and T/B ventilation system (IC)	Page 1/2 2/2	Missing of the unit description	Unit description [mSv/h] added
		-	PCV atmospheric radiation monitor (DW, S/C) A, C	Pages 1/3 , 3/3	Fluctuation of date and time description Clarification of the recorder outage time	Correction of date and time description Supplemental explanation on recorder outage is added
	Unit 5	No. 2	Reactor pressure	From 12 am to 12 pm, March 19	Missing of the data for the term	Page 10/12 added
		No. 6	RPV temperature	From 6 am, March 18 to 6 am, March 19	Missing of the data for the term	Pages 14/20 - 16/20 added
		No. 7	Radiation monitor at main exhaust stack (IC) C	Page 5/14	Pages 5 and 6 are duplicated.	Duplicated page (page 5) deleted and reorganized

	Unit 6	No. 1	POST ACCIDENT MONITORING SYSTEM A	Page 10/17	Pages 10 and 11 are duplicated	Duplicated page (page 10) deleted and reorganized
		No. 3	RHR B , RHR C , HPCS FLOW	Pages 8/28, 9/28, 12/28	Fluctuation of date and time description Clarification of the recorder outage time	Correction of date and time description Supplemental explanation on recorder outage is added
		No. 4	RHR Hx TEMP & REACTOR VESSEL TEMP REC	From 2 am to 2 pm, March 20	Missing of the data for the term	Pages 20/22, 21/22 added
		No. 5	AC SYS DRYWELL TEMP	Pages 18/22 – 22/22	Pages 18 to 22 are duplicated with the SRNM data	Pages 18 – 22 deleted
		No. 6	RECIRC PUMP SUCTION TEMPERATURES	From 1 pm, March 17 to 1 pm, March 18	Missing of the data for the term	Pages 9/13, 10/13 added
Data such as alarm message	Unit 5	-	Alarm message	Pages 4499, 4502, 4505	Missing of the page	Page 4505 added Data missing of page 4499 and 4502 is stated on pages 4498 and 4501.

(2) Fukushima Daini Nuclear Power Station (Data missing: 2, Data duplication: 0, Others [e.g. incorrect description]: 1)

Data	Unit (Homepage)		Data item	Time or page [before correction]	Check result (missing, duplication, and so on)	Responses [correction content]
Chart	Unit 2	No. 2	RCIC pump output flow	13/31 page, 16/31 page, 30/31 page	No abbreviated description	
Data such as alarm message	Unit 1	No. 3	Alarm message	March 11, 167 page	Missing of the data for the term	Page 167 added
	Unit 3	No. 4	Alarm message	March 12, 67 page	Missing of the data for the term	Page 67 added

Since there is no major changes of indication from 7:48 pm to 8:07 pm on March 11 and from 9:25 pm to 9:44 pm on March 11, chart is not shown for the period. The explanation for this is stated for the related pages since it was not stated.

End