

Table 8 External Dose Distribution Table by Month

Date	TEPCO/ Contractor	1 or less	1-5	5-10	10-20	20-50	50-75	75-100	100-150	150-200	200-250	Over 250	Workers	Max. dose	Average dose
201103	TEPCO	72	76	523	601	290	64	41	20	6			1693	182.33	19.41
	Contractor	551	760	385	331	182	36	22	8	3			2278	199.42	9.08
	Total	623	836	908	932	472	100	63	28	9			3971	199.42	13.48
201104	TEPCO	250	298	852	179	61	1						1641	59.60	6.56
	Contractor	1655	1442	582	406	106							4191	48.10	4.03
	Total	1905	1740	1434	585	167	1						5832	59.60	4.74
201105	TEPCO	442	770	169	71	14							1466	32.70	3.11
	Contractor	2255	2391	782	307	68							5803	48.80	3.19
	Total	2697	3161	951	378	82							7269	48.80	3.18
201106	TEPCO	525	711	81	30								1347	16.29	2.07
	Contractor	2505	2603	739	322	60							6229	43.00	3.00
	Total	3030	3314	820	352	60							7576	43.00	2.83
201107	TEPCO	678	609	49	17	3							1356	31.13	1.64
	Contractor	2846	2722	580	195	31							6374	34.42	2.39
	Total	3524	3331	629	212	34							7730	34.42	2.26
201108	TEPCO	561	652	55	19	1							1288	23.33	1.69
	Contractor	2816	2708	485	161	24							6194	36.10	2.18
	Total	3377	3360	540	180	25							7482	36.10	2.10
201109	TEPCO	545	618	38	2								1203	11.35	1.43
	Contractor	2842	2567	398	140	22							5969	33.40	2.01
	Total	3387	3185	436	142	22							7172	33.40	1.92
201110	TEPCO	577	536	43	15	3							1174	35.30	1.55
	Contractor	2815	2344	336	103	8							5606	23.50	1.84
	Total	3392	2880	379	118	11							6780	35.30	1.79
201111	TEPCO	851	280	37	10								1178	13.40	1.07
	Contractor	3350	1909	227	81	5							5572	23.03	1.46
	Total	4201	2189	264	91	5							6750	23.03	1.39
201112	TEPCO	867	282	26	13	3							1191	23.20	1.10
	Contractor	3339	1725	258	76								5398	19.20	1.44
	Total	4206	2007	284	89	3							6589	23.20	1.37
201201	TEPCO	759	284	37	13								1093	17.00	1.19
	Contractor	3239	1429	203	72	1							4944	21.90	1.36
	Total	3998	1713	240	85	1							6037	21.90	1.33
201202	TEPCO	845	231	25	8								1109	17.63	0.91
	Contractor	2948	1574	221	100	2							4845	20.91	1.50
	Total	3793	1805	246	108	2							5954	20.91	1.39
201203	TEPCO	875	220	23	2								1120	12.10	0.83
	Contractor	3030	1462	206	53	3							4754	21.83	1.36
	Total	3905	1682	229	55	3							5874	21.83	1.26
201204	TEPCO	868	179	19	3								1069	13.00	0.75
	Contractor	2836	1304	151	75	3							4369	23.90	1.30
	Total	3704	1483	170	78	3							5438	23.90	1.19
201205	TEPCO	853	177	10	1								1041	10.20	0.66
	Contractor	2897	1406	246	49								4598	18.22	1.42
	Total	3750	1583	256	50								5639	18.22	1.28

Date	TEPCO/ Contractor	1 or less	1-5	5-10	10-20	20-50	50-75	75-100	100-150	150-200	200-250	Over 250	Workers	Max. dose	Average dose
201206	TEPCO	827	162	20	3								1012	12.10	0.78
	Contractor	3086	1652	220	29								4987	14.94	1.29
	Total	3913	1814	240	32								5999	14.94	1.21
201207	TEPCO	857	150	9									1016	6.60	0.62
	Contractor	3065	1621	222	38								4946	17.33	1.34
	Total	3922	1771	231	38								5962	17.33	1.21
201208	TEPCO	839	144	7									990	7.20	0.62
	Contractor	3299	1341	120	4								4764	11.64	1.04
	Total	4138	1485	127	4								5754	11.64	0.97
201209	TEPCO	851	123	9									983	8.20	0.57
	Contractor	3272	1274	163	29	1							4739	20.50	1.15
	Total	4123	1397	172	29	1							5722	20.50	1.05
201210	TEPCO	827	145	7									979	6.30	0.61
	Contractor	3307	1325	136	31								4799	16.00	1.11
	Total	4134	1470	143	31								5778	16.00	1.03
201211	TEPCO	812	149	7									968	9.50	0.61
	Contractor	3306	1222	145	27								4700	18.70	1.09
	Total	4118	1371	152	27								5668	18.70	1.01
201212	TEPCO	848	149	10									1007	7.50	0.58
	Contractor	3489	1363	180	10								5042	15.00	1.10
	Total	4337	1512	190	10								6049	15.00	1.01
201301	TEPCO	871	96	3									970	7.39	0.42
	Contractor	3768	1310	115	7								5200	12.90	0.96
	Total	4639	1406	118	7								6170	12.90	0.88
201302	TEPCO	871	105	2									978	5.43	0.45
	Contractor	3916	1415	263	35								5629	18.50	1.21
	Total	4787	1520	265	35								6607	18.50	1.09
201303	TEPCO	846	140	10	2								998	11.03	0.60
	Contractor	3907	1706	335	35								5983	19.30	1.35
	Total	4753	1846	345	37								6981	19.30	1.24
201304	TEPCO	949	108	4									1061	5.90	0.49
	Contractor	4029	1165	111	5								5310	14.40	0.88
	Total	4978	1273	115	5								6371	14.40	0.81
201305	TEPCO	897	100	4									1001	8.60	0.45
	Contractor	3920	1141	92	5								5158	15.80	0.85
	Total	4817	1241	96	5								6159	15.80	0.78
201306	TEPCO	932	87	6									1025	7.40	0.42
	Contractor	3731	1182	85	7								5005	17.50	0.87
	Total	4663	1269	91	7								6030	17.50	0.79
201307	TEPCO	892	96	1									989	5.50	0.43
	Contractor	3752	1128	107	9								4996	14.80	0.89
	Total	4644	1224	108	9								5985	14.80	0.81
201308	TEPCO	834	118	4									956	6.10	0.49
	Contractor	3665	1211	142	40								5058	19.89	1.03
	Total	4499	1329	146	40								6014	19.89	0.94
201309	TEPCO	933	102	3									1038	5.60	0.44
	Contractor	3525	1420	247	61	1							5254	20.58	1.28
	Total	4458	1522	250	61	1							6292	20.58	1.14
201310	TEPCO	893	146	8									1047	9.50	0.55
	Contractor	3460	1556	343	47								5406	19.36	1.43
	Total	4353	1702	351	47								6453	19.36	1.29

Date	TEPCO/ Contractor	1 or less	1-5	5-10	10-20	20-50	50-75	75-100	100-150	150-200	200-250	Over 250	Workers	Max. dose	Average dose
201311	TEPCO	954	120	5									1079	9.20	0.48
	Contractor	3700	1533	303	32								5568	16.91	1.28
	Total	4654	1653	308	32								6647	16.91	1.15
201312	TEPCO	968	116	2									1086	5.40	0.44
	Contractor	3852	1627	199	23								5701	16.81	1.13
	Total	4820	1743	201	23								6787	16.81	1.02
201401	TEPCO	997	84										1081	4.50	0.37
	Contractor	4112	1505	221	53								5891	15.80	1.16
	Total	5109	1589	221	53								6972	15.80	1.04
201402	TEPCO	1018	56	4									1078	6.50	0.34
	Contractor	4611	1611	168	30								6420	17.29	1.02
	Total	5629	1667	172	30								7498	17.29	0.92
201403	TEPCO	1012	85										1097	4.80	0.36
	Contractor	4940	1867	227	23								7057	18.49	1.07
	Total	5952	1952	227	23								8154	18.49	0.98
201404	TEPCO	999	94	1									1094	5.70	0.38
	Contractor	5449	1743	234	19								7445	16.00	0.98
	Total	6448	1837	235	19								8539	16.00	0.91
201405	TEPCO	1053	65	1									1119	5.60	0.31
	Contractor	5974	1794	209	47	1							8025	20.70	0.95
	Total	7027	1859	210	47	1							9144	20.70	0.87
201406	TEPCO	1056	66	1									1123	6.80	0.32
	Contractor	6768	1790	329	26								8913	16.89	0.95
	Total	7824	1856	330	26								10036	16.89	0.88
201407	TEPCO	1092	39	1									1132	5.40	0.27
	Contractor	7292	1728	258	49								9327	18.69	0.89
	Total	8384	1767	259	49								10459	18.69	0.82
201408	TEPCO	1062	39										1101	3.40	0.25
	Contractor	7806	1338	214	9								9367	17.13	0.72
	Total	8868	1377	214	9								10468	17.13	0.67
201409	TEPCO	951	41	1									993	5.08	0.22
	Contractor	7619	1540	248	16								9423	16.37	0.77
	Total	8570	1581	249	16								10416	16.37	0.72

* The numbers of dose and workers are subject to change, due to replacement of APD data to monthly dose data measured by integral dosimeter and reflection of workers who wear integral dosimeter (example: workers who entered only the Main Anti-earthquake Building).