

(Aggregation period: March 11, 2011 - December 31, 2015)

Table 16 Cumulative Data of Equivalent Dose to the Lens of the Eye by Fiscal Year

FY2011

Dose ranges (mSv)	March 2011-March 2012		
	TEPCO's employees	Contractors	Total
Above 200	0	0	0
150-200	7	3	10
100-150	59	8	67
75-100	108	29	137
50-75	233	236	469
20-50	671	2490	3161
10-20	555	2818	3373
5-10	427	2565	2992
1-5	599	4713	5312
1 or less	756	4847	5603
Total	3415	17709	21124
Maximum (mSv)	188.14	199.42	199.42
Average (mSv)	19.21	9.34	10.93

•Equivalent dose is a measure of the radiation dose to organs and tissues, and the equivalent dose limit to the lens of the eye is 150mSv/year (the emergency exposure dose limit is 300mSv).

•Seven TEPCO's employees and three contractors shown in the "150-200"cell of the dose range above were exposed to radiation during the period when the dose limit for radiation workers engaged in emergency work was set at 300mSv.

FY2012

Dose ranges (mSv)	April 2012-March 2013		
	TEPCO's employees	Contractors	Total
Above 150	0	0	0
100-150	0	0	0
75-100	0	0	0
50-75	1	54	55
20-50	65	733	798
10-20	133	1970	2103
5-10	259	1843	2102
1-5	580	3294	3874
1 or less	588	4222	4810
Total	1626	12116	13742
Maximum (mSv)	55.60	67.30	67.30
Average (mSv)	4.55	6.31	6.10

FY2013

Dose ranges (mSv)	April 2013-March 2014		
	TEPCO's employees	Contractors	Total
Above 150	0	0	0
100-150	0	1	1
75-100	0	1	1
50-75	2	35	37
20-50	52	837	889
10-20	100	2049	2149
5-10	210	1828	2038
1-5	644	3619	4263
1 or less	684	4684	5368
Total	1692	13054	14746
Maximum (mSv)	68.30	106.88	106.88
Average (mSv)	3.78	6.10	5.83

FY2014

Dose ranges (mSv)	April 2014-March 2015		
	TEPCO's employees	Contractors	Total
Above 150	0	0	0
100-150	0	0	0
75-100	0	0	0
50-75	1	70	71
20-50	12	1233	1245
10-20	68	2604	2672
5-10	159	2640	2799
2-5	630	5183	5813
2 or less	818	7312	8130
Total	1688	19042	20730
Maximum (mSv)	56.50	62.91	62.91
Average (mSv)	2.42	5.97	5.68

FY2015

Dose ranges (mSv)	April 2015-December 2015		
	TEPCO's employees	Contractors	Total
Above 150	0	0	0
100-150	0	0	0
75-100	0	0	0
50-75	0	18	18
20-50	2	592	594
10-20	34	1582	1616
5-10	98	1978	2076
1-5	421	4761	5182
1 or less	1084	6460	7544
Total	1639	15391	17030
Maximum (mSv)	23.66	73.57	73.57
Average (mSv)	1.50	4.39	4.11

Note)

• The values of the exposure dose and the number of the workers in the table above are subject to change, because there are times when APD data are replaced with monthly dose data measured by integral dosimeters. Or the dose data of workers who wore only an integral dosimeter (ex., workers who entered only the Main Anti-earthquake Building) need to be updated in the table after the publication of the data.