

集中廃棄物処理施設周辺 サブドレン水核種分析結果

I-131 (Bq/L)

測定場所	2/7	2/8	2/9	2/10	2/11	2/12	2/13	2/14	2/15	2/16	2/17	2/18	2/19	2/20	2/21	2/22	2/23	2/24	2/25	2/26
①	ND (4.7)	ND (4.8)	ND (4.3)	ND (4.6)	ND (4.7)	ND (3.9)	ND (4.9)	※1	ND (4.0)	ND (4.2)	ND (4.6)	ND (4.3)	ND (3.8)	ND (5.4)	ND (5.4)	ND (4.2)	ND (5.5)	ND (5.4)	ND (4.8)	ND (4.3)
②	ND (3.0)	ND (4.7)	ND (4.8)	ND (3.6)	ND (5.1)	ND (4.6)	ND (4.8)	※1	ND (5.1)	ND (4.8)	ND (4.3)	ND (4.4)	ND (4.3)	ND (3.6)	ND (4.4)	ND (4.0)	ND (4.2)	ND (4.0)	ND (5.0)	ND (4.6)
③	ND (4.9)	ND (5.5)	ND (3.9)	ND (5.0)	ND (4.8)	ND (5.0)	ND (3.7)	※1	ND (5.1)	ND (5.4)	ND (4.5)	ND (5.4)	ND (4.8)	ND (4.8)	ND (4.8)	ND (4.9)	ND (4.0)	ND (3.9)	ND (4.0)	ND (4.8)
④	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
⑤	ND (4.9)	ND (5.3)	ND (4.8)	ND (3.9)	ND (4.3)	ND (4.2)	ND (4.7)	※1	ND (4.2)	ND (4.7)	ND (5.1)	ND (4.8)	ND (4.8)	ND (3.9)	ND (5.3)	ND (4.5)	ND (3.4)	ND (4.7)	ND (4.6)	ND (4.4)
⑥	-	ND (4.9)	-	-	-	-	-	-	ND (4.0)	-	-	-	-	-	-	ND (4.2)	-	-	-	-
⑦	ND (5.1)	ND (5.0)	ND (5.4)	ND (5.6)	ND (5.2)	ND (5.3)	ND (4.8)	※1	ND (5.7)	ND (5.4)	ND (6.8)	ND (5.5)	ND (5.9)	ND (5.3)	ND (4.6)	ND (4.7)	ND (6.2)	ND (6.6)	ND (6.0)	ND (5.0)
⑧	ND (4.0)	ND (3.9)	ND (4.0)	ND (3.9)	ND (5.2)	ND (4.9)	ND (4.7)	※1	ND (4.7)	ND (4.8)	ND (4.2)	ND (4.3)	ND (4.7)	ND (4.6)	ND (4.6)	ND (4.8)	ND (4.7)	ND (5.2)	ND (5.4)	ND (3.5)
⑨	ND (5.1)	ND (4.2)	ND (4.3)	ND (4.6)	ND (5.4)	ND (3.4)	ND (3.9)	※1	ND (4.9)	ND (5.5)	ND (5.9)	ND (4.7)	ND (4.0)	ND (4.3)	ND (4.8)	ND (4.8)	ND (4.8)	ND (5.0)	ND (4.2)	ND (5.3)

Cs-134 (Bq/L)

測定場所	2/7	2/8	2/9	2/10	2/11	2/12	2/13	2/14	2/15	2/16	2/17	2/18	2/19	2/20	2/21	2/22	2/23	2/24	2/25	2/26
①	ND (4.1)	ND (4.1)	ND (3.0)	ND (4.1)	ND (3.6)	ND (5.5)	ND (3.5)	※1	ND (5.0)	ND (4.8)	ND (4.8)	ND (5.5)	ND (5.3)	ND (5.1)	ND (3.3)	ND (3.4)	ND (4.5)	ND (5.4)	ND (3.3)	ND (4.4)
②	ND (4.0)	ND (4.0)	ND (4.0)	ND (4.4)	ND (5.5)	ND (4.6)	ND (5.0)	※1	ND (4.0)	ND (4.0)	ND (4.5)	ND (5.3)	ND (4.6)	ND (3.7)	ND (3.8)	ND (4.3)	ND (4.0)	ND (4.8)	ND (4.3)	ND (4.3)
③	ND (3.5)	ND (6.1)	ND (4.8)	ND (4.6)	ND (5.4)	ND (5.1)	ND (4.6)	※1	ND (3.8)	ND (5.6)	ND (3.6)	ND (4.0)	ND (3.5)	ND (4.4)	ND (5.9)	ND (4.3)	ND (4.0)	ND (4.3)	ND (4.5)	ND (5.0)
④	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
⑤	ND (3.7)	ND (5.4)	ND (5.2)	ND (3.7)	ND (4.4)	ND (4.1)	ND (6.0)	※1	ND (3.7)	ND (3.7)	ND (5.2)	ND (5.3)	ND (3.3)	ND (4.6)	ND (4.7)	ND (4.5)	ND (4.3)	ND (3.7)	ND (3.9)	ND (5.5)
⑥	-	ND (4.8)	-	-	-	-	-	-	ND (3.9)	-	-	-	-	-	-	ND (3.9)	-	-	-	-
⑦	7.4	7.6	8.9	11	6.7	8.3	6.8	※1	15	14	9.4	8.8	14	8.9	7.2	6.8	11	15	15	21
⑧	ND (4.6)	ND (5.1)	ND (4.8)	ND (4.6)	ND (4.6)	ND (4.6)	ND (5.2)	※1	ND (4.5)	ND (4.4)	ND (3.5)	ND (5.2)	ND (4.8)	ND (3.4)	ND (4.1)	ND (5.1)	ND (5.7)	ND (3.5)	ND (4.0)	ND (5.5)
⑨	ND (3.2)	ND (5.0)	ND (5.8)	ND (4.8)	ND (4.4)	ND (5.3)	ND (5.7)	※1	ND (4.5)	ND (5.2)	ND (4.7)	ND (4.8)	ND (5.5)	ND (6.3)	ND (4.8)	ND (4.3)	ND (5.6)	ND (4.8)	ND (4.3)	ND (6.0)

Cs-137 (Bq/L)

測定場所	2/7	2/8	2/9	2/10	2/11	2/12	2/13	2/14	2/15	2/16	2/17	2/18	2/19	2/20	2/21	2/22	2/23	2/24	2/25	2/26
①	ND (4.7)	ND (4.7)	ND (4.4)	ND (3.2)	ND (4.7)	ND (4.6)	ND (4.0)	※1	ND (4.7)	ND (3.9)	ND (4.8)	ND (4.3)	ND (4.5)	ND (4.3)	ND (4.7)	ND (4.2)	ND (4.5)	ND (5.6)	ND (4.7)	ND (3.9)
②	ND (3.2)	ND (4.6)	ND (4.6)	ND (4.7)	ND (4.2)	ND (4.2)	ND (5.3)	※1	ND (4.1)	ND (3.3)	ND (3.8)	ND (3.9)	ND (3.9)	ND (3.8)	ND (4.3)	ND (4.7)	ND (4.0)	ND (3.9)	ND (3.4)	ND (4.4)
③	ND (6.1)	ND (4.7)	ND (4.1)	ND (4.7)	ND (4.5)	ND (4.8)	ND (4.3)	※1	ND (3.8)	ND (4.2)	ND (3.8)	ND (4.0)	ND (4.3)	ND (3.8)	ND (3.3)	ND (5.2)	ND (4.3)	ND (4.7)	ND (4.1)	ND (4.5)
④	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
⑤	ND (5.5)	ND (4.2)	ND (5.2)	ND (3.9)	ND (4.7)	ND (3.8)	ND (5.0)	※1	ND (4.1)	ND (4.7)	ND (4.1)	ND (3.3)	ND (4.7)	ND (4.1)	ND (4.9)	ND (3.7)	ND (4.3)	ND (4.4)	ND (4.4)	ND (4.7)
⑥	-	ND (5.1)	-	-	-	-	-	-	ND (4.4)	-	-	-	-	-	-	ND (4.8)	-	-	-	-
⑦	44	55	49	57	45	47	55	※1	48	58	71	45	69	68	44	47	64	68	70	60
⑧	ND (4.7)	ND (3.7)	ND (4.2)	ND (4.4)	ND (4.9)	ND (5.0)	4.2	※1	ND (4.7)	ND (4.3)	4.0	5.0	3.6	ND (4.6)	ND (4.3)	ND (3.9)	6.5	ND (3.9)	ND (3.9)	5.2
⑨	ND (5.8)	ND (4.3)	ND (3.8)	ND (3.2)	ND (4.9)	ND (5.1)	ND (3.6)	※1	ND (5.2)	ND (5.2)	ND (4.8)	ND (5.3)	ND (3.9)	ND (5.3)	ND (4.3)	ND (4.5)	ND (4.5)	ND (4.8)	ND (4.5)	ND (4.5)

※「-」はサンプリング・測定を実施していないことを示す。  
 ※⑥は④が採取不可となったため、地下水流の上流側として選定し、週1回程度の頻度で測定。(2011/4/29～)  
 ※⑦は地下水流の下流側であることから、追加で測定。(2011/5/26～)  
 ※⑧を追加で測定。(2011/5/30～)  
 ※⑨を追加で測定。(2011/8/2～)  
 ※NDは検出限界値未満を表し、( ) 内に検出限界値を示す。  
 ※1 悪天候により採取中止

<測定箇所>  
 ①4号T/B建屋南東  
 ②プロセス主建屋北東  
 ③プロセス主建屋南東  
 ④プロセス主建屋南西  
 ⑤雑固体廃棄物減容処理建屋南  
 ⑥サイトバンカ建屋南西  
 ⑦焼却工作建屋 西側  
 ⑧雑固体廃棄物減容処理建屋北  
 ⑨サイトバンカ建屋南東